



工程设计资质证书编号
建筑甲级:A113007169
园林甲级:A113007169
规划乙级:城规142010
市政乙级:A213007166
人防乙级:A213007166

中盛弘宇建设科技有限公司
Zhongsheng Hongyu Construction Technology Co., Ltd.

备注 NOTE
*本图经施工图审查机构及消防审批部门审查合格方可用于施工。
版权所有中盛弘宇建设科技有限公司所有，未经书面许可，不得擅
自使用、更改和复制等其它用途。
This drawing can only be used for construction after being
examined to be qualified and approved by Drawing Appraisal
Unit & Fire Control Committee. The copyright belongs to the
engineering design company. Without written permission, it's prohibited to use, change or copy
the drawing for other purposes.

合作设计单位 CO-OPERATED WITH

说明 EXPLAIN

审 定 APPROVED BY	文永涛	支永涛
审 核 VERIFIED BY	李 亮	
项目负责人 PROJECT CHIEF	宋志荣	宋志荣
专业负责人 PROFESSION CHIEF	支永涛	支永涛
校 对 CHECKED BY	周兴	周兴
设 计 DESIGNED BY	周浪	周浪

建设单位 CONSTRUCTION			
重庆华牧现代农业有限公司			
工程名称 PROJECT			
华牧现代农业生态循环智能化蛋鸡项目配电工程			
项目名称 SUB PROJECT			
图纸名称 DRAWING TITLE			
主要设备材料表			
工程编号 DRAW NO.			
阶段 PHASE	施工图	专业 DISCIPLINE	电 气
比例 SCALE		图号 DRAW NO.	
日期 DATE	2023.04	版本号 VERSION NUMBER	A

签字齐全 盖章有效

主要设备材料表

华牧现代农业智能化蛋鸡项目电力专线工程（主要设备）					
序号	名 称	型号及规格	单位	数量	备注
1	组合欧式箱式变压器（环网型）	内装SCB12-1600kVA/10-0.4kV	台	1	10±5%/0.4kV Uk%=6.0 DYn11
2	1000kW柴油发电机柜（进线）	双电源进线 GCS	面	1	FD0
3	1000kW柴油发电机柜（出线）	2路抽出式断路器柜 GCS	面	1	FD01
4	HTCK-2000A封闭母线槽	4芯防火型	米	16	1#柴油发电机上进线
5	单相立柱高压隔离开关	12-630A	只	3	专线终端杆用于电缆下线
6	10kV避雷器	HY5WS-17/50	只	3	专线终端杆用于电缆防雷

华牧现代农业智能化蛋鸡项目电力专线工程					
序号	名 称	型号及规格	单位	数量	备注
1	高压电力电缆（铜芯）	ZB-YJV22-8.7/15kV-3×95	米	30	1根（专线终端杆至箱变进线柜1ZG1）
2	10kV电缆终端	3×95, 户外终端, 冷缩, 铜	套	1	
3	10kV电缆终端	3×95, 户内终端, 冷缩, 铜	套	1	
4	10kV电缆终端	3×50, 户内终端, 冷缩, 铜	套	1	
5	防火堵料		公斤	30	
6	防火涂料		公斤	5	
7	镀锌接地扁钢	-60*6*6000mm, 焊接组网	块	3	不含箱变接地网
8	C形导线线夹（带罩）	JC-36	套	6	
9	C形设备线夹（带罩）	JC-51、JC-47、JC-48	套	17	
10	架空绝缘线	JKYJ-1kV-150	米	20	箱变接地线
11	架空绝缘线	JKLGJY-1kV-70/10	米	30	
12	架空绝缘线	JKLGJY-1kV-50/8	米	20	户外10kV避雷器接地线
13	电缆护套管	95--120, 冷缩, 铜	根	9	95电缆用
14	电缆抱箍	-60*6, 各型	付	4	
15	低压电力电缆（铜芯单芯）	WDZBN-YJY-1*300	米	620	电缆下进线、下出线
16	柴油发电机房电缆沟：宽*深=600*700	含电缆沟复合材料盖板	米	6	